



Propane Policies for Exhibitors

1. No combustible or flammable liquids or gases shall be used or admitted inside the building except for demonstration when approved in writing by the Oncenter Complex, County Fire Coordinator's Office and Syracuse Fire Prevention Bureau.
2. The use of any and all gas or solid fuel-fired heating unit, either portable or stationary, is prohibited except for limited duration for demonstrations. The Oncenter Management, County Fire Coordinator's Office and Syracuse Fire Prevention Bureau must approve any use of gas fueled heating units, on an individual basis.
3. When a gas or solid fuel heating unit is accepted by the Oncenter Complex, County Fire Coordinator's Office and Syracuse Fire Prevention Bureau, there will be inspections conducted during the course of the move-in and/or tear down. Combustible material shall be kept a minimum of three feet away from any heat source. Representatives of the Oncenter Complex, County Fire Coordinator's Office and Syracuse Fire Prevention Bureau will conduct a pre-opening inspection and a periodic inspection during the course of the trade show or exhibition.
4. When fuel is present, there will also be a portable dry chemical fire extinguisher with a classification of 4-A:60 B:C, (10# ABC extinguisher.) The fuel of propane, no more than 5#, will be accepted in the building per demonstration site. Only U.L. classification with D.O.T. rated 5# (12# water capacity) cylinder of propane will be acceptable, **nothing larger**. Propane cylinders shall be secured in a vertical position and clearly labeled for content.
5. Storage of propane in the building by exhibitors is prohibited other than what is in use for the display. The exhibitor is responsible for removing their fuel off site after each demonstration at the end of the day. Recommended procedure for removing the cylinders is to shut down the valve and let the fuel burn out of the line first. Then disconnect the hose from the tank. Exhibitors are responsible for making provisions for out-of-building storage of spare tanks.
6. The Oncenter Complex will be responsible for maintaining adequate air supply to ensure good air quality and minimum monoxide build up and will provide "No Smoking" signs at the site of use. The Oncenter Complex reserves the right to shut down any unit not complying with the above rules and regulations and if the quality of air is compromised. The above are subject to change as conditions and code regulations warrant